



KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Companies Act, 1956)

Reg. Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram - 695 004

CIN :U40100KL2011SGC027424, Website: www.kseb.in.

Phone: +91 471 2514576, 2446885, 9446008884, E-mail: dtksebl@ksebl.in

ABSTRACT

Dismantling of unused 66 kV line and towers from the land of M/s BPCL Kochi Refinery for their new Polyols Petro Chemical project- Sanctioned- Orders issued.

Corporate Office(SBU-T)

B.O.(FTD)No. 390/2020/D(T,SO&S)/T6/KLSY/BPCL-line dismantling/2020-21/175 dated Thiruvananthapuram 05.06.2020

- Read :
1. Letter No. CE(TS)/EE1/AEE II/BPCL-KR/66 kV KRL Tap line dismantling/2020-21/284 dated 25.05.2020 of the Chief Engineer, Transmission South.
 2. Note No. D (T,SO&S) /T6 / KLSY /BPCL- line dismantling /2020-21 /175 dated 28.05.2020 of the Director(T,SO&S) to the Full Time Directors (Agenda : 86/5/20).

ORDER

The Chief Engineer, Transmission South as per letter read as 1st above has requested sanction for dismantling 700 m of the 66 kV KRL Tap line between locations 17,18 and 19 including the towers at these locations as per the request of M/s BPCL -Kochi Refinery (BPCL-KR), on deposit work basis. It is also reported that M/s BPCL-KR is planning to set up Polyols Petro Chemical Project in their plot adjacent to Brahmapuram Sub Station through which the 66 kV KRL Tap line is passing through and hence BPCL has requested to dismantle the portion of the line passing through their plot.

The Chief Engineer has reported the following in this regard:-

- The 66 kV KRL tap line (from the 66kV Kalamassery- Vyttila (KLVT) fed power to BPCL earlier and after the construction of the 220 kV Ambalamugal Sub Station, BPCL started availing power from Ambalamugal Sub Station leaving the Tap line un energised since then.
- The structures including 1 no.Y type tower, 1 no. TTC tower, 1 no. TTA tower and the Mink conductors proposed for dismantling are also not in good condition and poses safety issues.
- BPCL has submitted an undertaking agreeing to honour the right of KSEBL on the ROW with regard to the line in case of a future need and have agreed to provide a mutually agreed route through their land when need arises.

The matter was placed before the Full Time Directors as per note read as 2nd above.

Having considered the above, the Full Time Directors, in the meeting held on 30.05.2020 resolved to accord sanction to the Chief Engineer (Transmission South) for dismantling 700 m of the 66 kV KRL Tap line between locations 17,18 and 19 including the towers at these locations as requested by M/s BPCL, on deposit work basis.

Orders are issued accordingly.

By Order of the Full Time Directors,

Sd/-

Lekha G.

Company Secretary (In- Charge)

To :

The Chief Engineer, Transmission South

Copy to:

The Deputy Chief Engineer, Transmission Circle, Kalamassery

The Deputy Chief Engineer(IT)

The Financial Adviser/ The Chief Internal Auditor.

The RCAO/ RAO.

The TA to Chairman & MD/ D(T,SO&S)/ D(D , IT&HRM)// D(G-C)/ D(G-E& SCM)

The PA to Director (Finance)/CA to Company Secretary

Fair Copy Superintendent/Library/Stock File.

Forwarded / By Order



Assistant Executive Engineer